

Er. A. SIVAKUMAR B.E., M.I.E, F.I.V, M.B.A., PGD - Hydrogeo., PGD CC Tech., PGD QS & Valuation. M.I.C.A.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District
to issue Structural soundness (stability) certificate to public Buildings Regd. No : H-3/26054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Sasvitha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakthi Housing Finance Pvt. Ltd. |

**Statement to accompany the certificate of
Structural soundness**

Ref No. 8824VS-II/0623

1. Location : **SHRI RAM SCHOOL BUILDING**
Street and name of the place : **New SF No. 125/1A, 2, 3, 4, 5, 6, 7A, 8, 9, 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14A, 15, 16A, 17A, Tenkodipakkam Village, Vanur Taluk, and SF Nos. 300/2A, 2B, 3A, Omandur Village, Tindivanam Taluk, Villupuram District.**
2. Age of the building : **09 years**
(Based on the local enquiry)
3. Approximate cost of construction as : **13.00 Crore**
Per Current Rates
4. Number of Storeys : **Three Storied Building**
5. Short description of structures steel : **Framed Structure**
RCC framed or load bearing masonry
6. Purpose for which the building is : **School Building (For Conducting Classes)**
Certified for use
7. The period for which building : **01.06.2023 to 31.05.2026**
Will be structurally sound
8. Number of persons to be accommodated : **1500 Pupil in all**

Date : 25.05.2023
Place : Ulundurpet

Er. A. SIVAKUMAR, B.E., M.I.E., F.I.V., M.B.A.,
Registered Engineer. Authorised by the
District Collector of Villupuram District
to issue Structural Soundness (Stability)
Certificate to Public Buildings. Registered Engineer
Regd. No: H-3/26054/08 Mobile : 98423-22127

Valuers, Planners, Designers and Consultants.

No: 3/22. A, Sameer Complex (First Floor), ALC Church (opp) Vriddhachalam Road,
Ulundurpet - 606 107. Kallakurichi District. Mobile : 9842322127. e-mail : sivaengr2016@gmail.com

Mr. A.SIVAKUMAR

B.E., M.I.E, F.I.V, M.B.A., PGD - Hydrogeo., PGD CC Tech., PGD QS & Valuation. M.I.C.A.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District
to issue Structural soundness (stability) certificate to public buildings Regd. No : H-3/26054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Sasvitha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakthi Housing Finance Pvt. Ltd. |

Statement Accompanying Form - A

1. Door Number of building : **SHRI RAM SCHOOL BUILDING**
2. Location : **OMANDURAR MEMORIAL**
Street and name of the place **New SF No. 125/1A, 2, 3, 4, 5, 6, 7A, 8, 9, 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14A, 15, 16A, 17A, Tenkodipakkam Village, Vanur Taluk, and SF Nos. 300/2A, 2B, 3A, Omandur Village, Tindivanam Taluk, Villupuram District.**
3. Year of construction : **2014**
(Based on local enquiry)
4. Approximate cost of construction as : **13.00 Crore**
Per Current Rates
5. Purpose for which the building is being : **School Building (For Conducting Classes)**
Certified for use or propose to be used
6. Purpose for which the building has now : **School Building (For Conducting Classes)**
Been used
7. Details of construction of the
Building (Particulars of the foundation soil,
Specification of the various parts under)
- (a) Foundation : **Framed Structure**
- (b) Basement : **RCC Column & Footings**
- (c) Superstructure : **Brick Masonry with Cement Mortar**
- (d) Floor Finishing : **Ceramic Tiles**
- (e) Roof : **RCC Roof**



Valuers, Planners, Designers and Consultants.

No: 3/22. A, Sameer Complex (First Floor), ALC Church (opp) Vriddhachalam Road,
Ulundurpet - 606 107. Kallakurichi District. Mobile : 9842322127. e-mail : sivaengr2016@gmail.com

Er. A. SIVAKUMAR B.E., M.I.E., F.I.V., M.B.A., PGD - Hydrogeo., PGD CC Tech., PGD QS & Valuation. M.I.C.A.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District
to issue Structural soundness (stability) certificate to public buildings Regd. No : H-3/26054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Sasvitha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakthi Housing Finance Pvt. Ltd. |

(f) Plinth Area Details (Existing Building):

Primary block

Ground Floor : 912.66 Sq.mt
First Floor : 810.78 Sq.mt
Second Floor : 810.78 Sq.mt

Secondary & senior secondary block

Ground Floor : 1376.67 Sq.mt
First Floor : 1376.67 Sq.mt
Second Floor : 1376.67 Sq.mt

8. Period for which Certification is Valid : 01.06.2023 to 31.05.2026
9. Number of person to be accommodated : 1500 Pupil in all

Date : 25.05.2023
Place : Ulundurpet

Er. A. SIVAKUMAR, B.E., M.I.E., F.I.V., M.B.A.,
Registered Engineer, Authorised by the
District Collector of Villupuram District
to issue Structural Soundness Certificate to Public Buildings,
Regd. No: H-3/26054/08 Mobile : 98423-22127

“Certified that no addition or alteration has been made to the Proposed Building of the Institution for which this application been made. I undertake to obtain a fresh license in case any addition or Alteration is made to the existing building or portion of building. I also undertake to obtain a fresh certificate if the purpose for which the license was granted for the use of the Institution originally is changed or altered subsequently.”

Date:

Signature of the Applicant.

Valuers, Planners, Designers and Consultants.

No: 3/22.A, Sameer Complex (First Floor), ALC Church (opp) Vriddhachalam Road,
Ulundurpet - 606 107. Kallakurichi District. Mobile : 9842322127. e-mail : sivaengr2016@gmail.com

Er. A.SIVAKUMAR

B.E., M.I.E, F.I.V, M.B.A., PGD - Hydrogeo., PGD CC Tech., PGD QS & Valuation. M.I.C.A.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District
to issue Structural soundness (stability) certificate to public buildings Regd. No : H-3/26054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Sasvitha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakthi Housing Finance Pvt. Ltd. |

FORM - B

(Form of Certificate of structural soundness under sub-section (4) of section 4 of the Tamil Nadu Public Building (Licensing) Act 1965 (Tamil Nadu Act 13 of 1965) referred to in rule 4 of the Tamil Nadu Public Building (licensing) Rules 1966)

I certify that I have inspected the **SHIRI RAM SCHOOL BUILDING, New SF No. 125/1A, 2, 3, 4, 5, 6, 7A, 8, 9, 10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14A, 15, 16A, 17A, Tenkodipakkam Village, Vanur Taluk, and SF Nos. 300/2A, 2B, 3A, Omandur Village, Tindivanam Taluk, Villupuram District.** Mentioned in the statement and finish below its salient technical features and the Same is based on the data measurements and specifications found in the site of the subject institution Physically:-

I. Foundation:

- | | | |
|--|---|--------------------------------------|
| Depth below Ground level
(For Proposed) | : | 2.00 M below the Ground level |
| Nature of soil met with at foundation
Level | : | Hard gravel |
| Pressure at foundation | : | 20.00 Ton / Sq. M |
| Probable safe bearing capacity of the
Soil met with at foundation | : | 20.00 Ton / Sq. M |

II. Superstructure:

- | | | |
|--|---|---|
| Maximum stress in the most critical
Section of masonry and concrete | : | The stresses are safe in most critical
Sections |
| Nature of masonry and concrete and
Its permissible stress | : | The stresses in stone, brick masonry and
RCC are within permissible limits and as
per design |

The structural soundness of the proposed building has been verified by me with reference to ISI loading standard 878 (Latest version) and other Relevant Indian Standards Code of practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in The statement. And may be stable and structurally sound for the Period **Three Years 01.06.2023 to 31.05.2026.**

Er. A. SIVAKUMAR, B.E., M.I.E., F.I.V., M.B.A.,
Registered Engineer Authorised by the
District Collector of Villupuram District
to issue Structural Soundness (Stability)
Certificate to Public Buildings

Date : 25.05.2023

Place: **Valuers, Planners, Designers and Consultants.**

No: 3/22. A, Sameer Complex (First Floor), ALC Church Road, Vridhachalam, Villupuram, Tamil Nadu, 606 107. Kallakurichi District. Mobile: 9842322127. e-mail: sivaengr2016@gmail.com

Er. A. SIVAKUMAR B.E., M.E., FIV., M.B.A., PGD-Hydragen., PGD-CC Tech., PGD-CE & Valuation, M.I.C.E.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District to issue Structural soundness (stability) certificate to public Buildings Regd. No : H-3/20054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Saswatha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakti Housing Finance Pvt. Ltd. |

FORM-C

Form of report to be made to the competent authority by inspecting authorities or officers appointed under other act under section 25 of the Madras Public Building Licensing Act 1965 (Madras act 13 of 1965) referred to rule 7 of the Madras Public Building Licensing rule 1966

- i. Name and designation of inspecting Authority or officer appointed or having Jurisdiction under any other act or law : **A. SIVAKUMAR**
No.05, EAST KANDHASAMPURAM,
SSV SCHOOL OPPOSITE,
ULUNDURPET - 606 107.
KALLAKURICHI DISTRICT.
MOBILE: 98423 22127.
- ii. Location of the building inspected Door. No, Street No, Name of the place i.e. Municipal Corporation / Municipality/ Panchayath / Panchayath Union/Township / Cantonment : **SHRI RAM SCHOOL BUILDING**
New SF No.125/1A, 2, 3, 4,5,6,7A,8,9,
10A, 11A, 126/1, 2, 3, 4, 5, 6, 7, 8, 9, 10,
11, 12, 13, 14A, 15, 16A, 17A,
Tenkodipakkam Village, Vanur Taluk,
and SF No.300/2A, 2B, 3A, Omandur
Village, Tindivanam Taluk, Villupuram
District.
- iii. Date of inspection : **20.05.2023**
- iv. Purpose for which the building is used : **School Building**
(For Conducting Classes)
- v. Nature of defects noticed : **Nil**
- vi. Suggestion for rectifying defects : **No defects**
- vii. If in dangerous condition immediate action recommended to be taken : **No**

Place : Ulundurpet
Date : 25.05.2023

Er. A. SIVAKUMAR, B.E., M.E., FIV., M.B.A.
Registered Engineer Authorised by the
District Collector of Villupuram District
to issue Structural Soundness (Stability)
Certificate to Public Buildings
Regd. No. H-3/20054/08 Mobile : 98423-22127

Valuers, Planners, Designers and Consultants.

No. 3/22.A, Sameer Complex (First Floor), ALC Church (opp) Vriddhachalam Road,
Ulundurpet - 606 107, Kallakurichi District. Mobile : 9842322127. e-mail : sivaengr2016@gmail.com

Er. A. SIVAKUMAR B.E., M.I.E, F.I.V, M.B.A., PGD - Hydrogeo., PGD CC Tech., PGD QS & Valuation. M.I.C.A.

Chartered Civil Engineer (India)

(Registered Engineer, Authorised by the District Collector of Villupuram District
to issue Structural soundness (stability) certificate to public buildings Regd. No : H-3/26054/08)

- | | |
|--|--|
| <input type="checkbox"/> Approved Valuer APAC Financial Service Pvt. Ltd | <input type="checkbox"/> Approved Valuer Swarna Pragathi Housing Micro Finance |
| <input type="checkbox"/> Approved Valuer Mahindra Home Finance | <input type="checkbox"/> Approved Valuer HDB Financial Service |
| <input type="checkbox"/> Approved Valuer Federal Bank | <input type="checkbox"/> Approved Valuer Repco Home Finance Ltd., |
| <input type="checkbox"/> Approved Valuer Sasvitha Home Finance Pvt. Ltd. | <input type="checkbox"/> Approved Valuer Varashakthi Housing Finance Pvt. Ltd. |

DECLARATION

I, A. SIVAKUMAR Son of Thiru. M.S. ANBAIYA residing at No.05, East Kandasampuram, Ulundurpet, do hereby declare that I possess the qualification and experience specified in the Table to rule 11, of the Madras Public Buildings (Licensing) Rules 1966, for issuing the Certificate of Structural Soundness of the building covered by the certificate.

i) Name and address : **A. SIVAKUMAR,**
(in Block letters) **No.05, EAST KANDHASAMPURAM,**
SSV SCHOOL OPPOSITE,
ULUNDURPET - 606 107.
KALLAKURICHI DISTRICT.
MOBILE: 98423 22127.

ii) Engineering qualification : **B.E (CIVIL)**

iii) No. of years of experience
and nature thereof. : **29 Years**

iv) Villupuram Collectorate
Registration No. : **H - 3/ 26054 / 08 dated on 07.07.2008**

Note: This Certificate will not be valid in the event of:

- Fire Accident.
- Natural disasters like Earth quake, flood, cyclone, etc.,
- Any major changes like demolishing or alterations in the building - without Technically Qualified Engineers connections.
- Non-maintenance and unrepaired civil works in the building.
- Any accidents/ damages caused by the surrounding neighbor's building/factory.

(Form of opinion under sub - section (1) of section 5 of the Madras Public Buildings (Licensing) Act 1965 (Madras Act 13 of the 1965 referred to in rule 5 of the Madras Public Buildings (Licensing) Rules 1966) I have inspected the building specified in the statement below and I have satisfied myself that the Existing building is structurally sound to be used as a Public Building for the purpose specified in the statement. The structural soundness of the building has been verified taking into account the loading as per the latest Indian Standards 875. I am therefore of the opinion that a license may be granted for the period **Three Years 01.06.2023 to 31.05.2026.**

Er. A. SIVAKUMAR, B.E., M.I.E., F.I.V., M.B.A.,
Registered Engineer, Authorised by the
District Collector of Villupuram District
to issue Structural Soundness (Stability)
Certificate to Public Buildings,
Regd. No: H-3/26054/08, Mobile: 98423 22127

Place : Ulundurpet
Date : 25.05.2023

Valuers, Planners, Designers and Consultants.

No: 3/22.A, Sameer Complex (First Floor), ALC Church (opp) Vriddhachalam Road,
Ulundurpet - 606 107. Kallakurichi District. Mobile: 9842322127. e-mail: sivaengr2016@gmail.com

PROCEEDINGS OF THE COLLECTOR, VILUPPURAM DISTRICT, VILUPPURAM.

Present: Dr. R. Palanisamy, I. A. S.,

H3/26054/08

Dated: 7-7-08

SUB:- TAMIL NADU PUBLIC BUILDING Licensing Act 1965 - Inclusion of the Name of Thiru A. Sivakumar in the panel of private practising Engineer under Class-II in Viluppuram District - orders issued.

- Ref: 1) petition of Thiru A. Sivakumar, Ulundurpet dated 12.8.06.
2) This Office ref.K.Bis.(C2)31602/06 dated 22.2.08.
3) Chennai, Chempauk, Engineer-in-Chief, N. R.O. and Chief Engineer (General) P. W. D. Dr.No.AEE/TI/27571/08, dated 30.4.08.
4) Thiru A. Sivakumar, Ulundurpet petition dated 20.6.08.

ORDER:

Thiru A. Sivakumar, B. E. (Civil) has presented an application to the Collector of Viluppuram for registering his name in the panel of Engineers under Class-II category. In this connection his application was forwarded to the Chief Engineer, Public Works Department, Chennai-5 through Superintending Engineer (P. W. D.) Salem-7.

2) The Board of Engineers in the 470th meeting held on 28.3.08 has recommended to include his name in the panel of private practising Engineers under Class-II for the Viluppuram District.

3) Accordingly the name of Thiru A. Sivakumar is ordered to be included in the panel of private practising Engineers under Class-II for the

.....2.

A Sivan
E.A.SIVAKUMAR, B.E. MSA, FIV.,
Chartered Civil Engineer (AM 026093-6),
A. S. Sivan, (E-122/01),
P. O. Box 22127,
Chennai - 600 023

