

TAMILNADU FIRE & RESCUE SERVICE DEPARTMENT

FIRE SAFETY CERTIFICATE

LICENSE NO : 57/2025

DATE :26-11-2025

K.Dis.NO : 508/V/2025 ; 21.10.2025

Sub :Fire – Rescue Department ,Tindivanam Fire – Rescue Station – To start School / for approval of school to furnish no objection certificate- Reg

View: 1) G.O. NO.122 School Education (2) Department dated 14-09-2004
2) G.O.NO. 123 School Education (3) Department dated 14-09-2004
3) Application received from **The Chairman,Shri Ram School CBSE Tindivanam.**

Under the perusal of Govt. order and application of , “SHRI RAM SCHOOL CBSE”, at Omandur Village, Tindivanam Taluk,Villupuram District-604102 has complied with the fire prevention and the fire safety requirements in accordance with State Fire Service Rules and where the above school was inspected by Station Officer MR.V.RAJA on 26 -11-2025 there is no objection to run the school in the above said premises.

Conditions :

1. This License is valid for ONE YEAR from the date of issue.
2. For safety systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per sq. meter as per the National Building code 2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As per para 6.3 of the BIS standards IS 14435:1997 as the classrooms have only one entrance the capacity of the class rooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Villupuram District
6. If any extension or alteration is made in the existing building and also for changing of present business will also apply and get separate permission.
7. Regular license ha to be obtained from competent authority.
8. If here is any deviation from the Govt. Rule and act the License issued will stand cancelled.

TO

Mr.S.RAGURAMAN,
Secretary,
SHRI RAM SCHOOL CBSE,
Omandur Village,Tindivanam TK,
Villupuram District-604 102.

இ. ராஜா 26/11/25
நிலைய அலுவலர்
தீயணைப்பு மீட்பு பணிகள் நிலையம்
திண்டிவனம் - 604 001

Copy to:

1. District Fire Officer Villupuram District.
2. Concerned Certificate Issuing Authority.